

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0521

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

KFP-AF2 Two Loop Intelligent Analogue Addressable Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Carrier Fire & Security B.V.
Kelvinstraat 7
NL-6003 DH
Weert
Netherlands

and produced in the manufacturing plant(s):

Carrier Manufacturing Poland Spółka Z o.o.
ul. Kolejowa 24
Ropczyce
39-100
Poland

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power Supply Equipment
EN 54-21:2006 - Alarm Transmission and Fault Warning Routing Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



E Mattie-Suleiman, Certification Engineer

Date of First Issue: 23 October 2019

Date of Issue: 14 March 2023

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0521

KFP-AF2 Two Loop Intelligent Analogue Addressable Control and Indicating Equipment

The details and conditions of use for the KFP-AF2 two loop intelligent analogue addressable control and indicating equipment placed on the market by Carrier Fire & Security B.V., Kelvinstraat, NL-6003 DH, Weert, The Netherlands are:

To be used in accordance with the suppliers installations instructions and in conjunctions with the following bases ancillaries, sounder tones and sensitivity settings (where applicable):

- KFP-AF2** Intelligent Analogue Addressable Control and Indicating Equipment with User Interface - 2 Loop
- KFP-AF2-PRT** Intelligent Analogue Addressable Control and Indicating Equipment with user interface - 2 loop with printer
- KFP-AF2-S** Intelligent Analogue Addressable Control and Indicating Equipment with user interface - 2 loop small cabinet

Incorporating the following units:

2010-2F2-MB	Main control board
KFP-A-UI	User interface control board
2010-2-PS-40 using LRS-100-24	4A Power Supply

Incorporating the following optional modules:

KFP-A-ZI-20	(20 Zone) (Large cabinet variant only)
KFP-A-ZI-40	(40 Zone) (Large cabinet variant only)
KFP-A-ZI-24-S	(24 Zone) (Small cabinet variant only)
2010-2-NB	Network card
KFP-A-LB	Loop Board (Large cabinet variant only)
2010-2-232-KIT	Interface board for external printer
2010-2-PS-C2	UK mains cable for large cabinet
2010-2-PS-C2-S	UK mains cable for small cabinet
2010-2-PRT	Door mounted printer module (KFP-A-F2-PRT variant only)
2010-2-PIB-8O	Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I	Peripheral Interface Board 8 inputs (Large cabinet variant only)
2010-2-PIB-8I8O	Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)
2010-2-DACT	With ATS7310 (GSM module)
2010-FS-EOL	Fault Supervision End of Line unit



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 14 March 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0521

KFP-AF2-FB2 Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop

KFP-AF2-FB2-PRT Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop with Printer

KFP-AF2-FB2-S Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop Small Cabinet

Incorporating the following units:

2010-2F2-MB	Main control board
KFP-A-UI-FB2	User interface control board
2010-2-PS-40 using LRS-100-24	4A Power Supply

Incorporating the following optional modules:

KFP-A-ZI-20	(20 Zone) (Large cabinet variant only)
KFP-A-ZI-40	(40 Zone) (Large cabinet variant only)
KFP-A-ZI-24-S	(24 Zone) (Small cabinet variant only)
2010-2-NB	Network card
KFP-A-LB	Loop Board (Large cabinet variant only)
2010-2-232-KIT	Interface board for external printer
2010-2-PS-C2	UK mains cable for large cabinet
2010-2-PS-C2-S	UK mains cable for small cabinet
2010-2-PRT	Door mounted printer module (KFP-A-F2-FB2-PRT variant only)
2010-2-PIB	Peripheral Interface Board (Germany) (Large cabinet variant only)
2010-2-PIB-8O	Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I	Peripheral Interface Board 8 inputs (Large cabinet variant only)
2010-2-PIB-8I8O	Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)
ADP-N3E-U	(Large cabinet variant only)
ADP-N3S	(Large cabinet variant only)
2010-2-DACT	With ATS7310 (GSM module)
2010-FS-EOL	Fault Supervision End of Line unit



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 14 March 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0521

KFP-AF2-SCFB Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with SS3654 Fire Brigade Controls - 2 Loop with Scandinavian Key Switch

KFP-AF2-SCFB-S Intelligent Analogue Addressable Control and Indicating Equipment with User Interface with SS3654 Fire Brigade Controls - 2 Loop Small Cabinet with Scandinavian Key Switch

Incorporating the following units:

2010-2F2-MB	Main control board
KFP-A-UI-SCFB	User interface control board
2010-2-PS-40 using LRS-100-24	4A Power Supply

Incorporating the following optional modules:

KFP-A-ZI-20	(20 Zone) (Large cabinet variant only)
KFP-A-ZI-40	(40 Zone) (Large cabinet variant only)
2010-2-NB	Network card
KFP-A-LB	Loop Board (Large cabinet variant only)
2010-2-232-KIT	Interface board for external printer
2010-SK	Scandinavian key and lock assembly
2010-2-PS-C2	UK mains cable for large cabinet
2010-2-PS-C2-S	UK mains cable for small cabinet
2010-2-PRT	Door mounted printer module (KFP-A-F2-SCFB-PRT variant only)
2010-2-PIB-8O	Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I	Peripheral Interface Board 8 inputs (Large cabinet variant only)
2010-2-PIB-8I8O	Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)
2010-2-DACT	With ATS7310 (GSM module)
2010-FS-EOL	Fault Supervision End of Line unit

KFP-AE2-S Intelligent Analogue Addressable Fire and Evacuation Control and Indicating Equipment with User Interface with Fire Brigade Controls - 2 Loop Small Cabinet

Incorporating the following units:

2010-2F2-MB	Main control board
KFP-A-UI-E	User interface control board
2010-2-PS-40 using LRS-100-24	4A Power Supply

Incorporating the following optional modules:

KFP-A-ZI-20	(20 Zone) (Large cabinet variant only)
-------------	--



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 14 March 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0521

KFP-A-ZI-40	(40 Zone) (Large cabinet variant only)
KFP-A-ZI-24-S	(24 Zone) (Small cabinet variant only)
2010-2-NB	Network card
KFP-A-LB	Loop Board (Large cabinet variant only)
2010-2-232-KIT	Interface board for external printer
2010-2-PS-C2	UK mains cable for large cabinet
2010-2-PS-C2-S	UK mains cable for small cabinet
2010-2-PIB-8O	Peripheral Interface Board 8 outputs (Large cabinet variant only)
2010-2-PIB-8I	Peripheral Interface Board 8 inputs (Large cabinet variant only)
2010-2-PIB-8I8O	Peripheral Interface Board 8 outputs and 8 inputs (Large cabinet variant only)
2010-2-DACT	With ATS7310 (GSM module)
2010-FS-EOL	Fault Supervision End of Line unit

The above fire panels are certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm device(s)
- 7.9.1 Output to fire alarm routing equipment (not available on KFP-AF2, KFP-AF2-PRT and KFP-AF2-S)
- 7.9.2 Alarm confirmation input from fire alarm routing equipment (not available on KFP-A-F2, KFP-AF2-PRT and KFP-AF2-S)
- 7.10 Output to fire protection equipment - Type A,B and C (not available on KFP-A-F2, KFP-A-F2-PRT and KFP-A-F2-S)
- 7.11 Delays to outputs
- 7.12 Dependencies on more than one alarm signal (Type A, B and C)
- 7.13 Alarm counter
- 8.4 Total loss of the power supply
- 8.9 Output to fault warning routing equipment
- 9.5 Disabling of addressable points
- 10 Test condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN 54-13.
2. Available with the following language kit options:
01 Dutch (NL) The Netherlands, 02 French (FR) France, 03 English (UK) United Kingdom and Ireland, 04 German (DE) Germany, 05 Norwegian Norway, 06 Swedish Sweden, 07 Danish (DK) Denmark, 08 English (AU) Australia, 09 Spanish Spain, 10 Italian Italy, 11 Dutch (BE) Belgium, 12 Irish Ireland, 13 German (AU) German (Austria), 14 Greek Greece, 15 Arabic Middle East, 17 English (US) United States of America, 18 Polish Poland, 19 Turkish Turkey, 20 Czech Czech



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 14 March 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0521

Republic, 21 Portuguese Portugal, 22 Hungarian Hungary, 23 Danish (IC) Iceland, 24 Slovakian Slovak Republic, 25 Russian Russia, 27 Lithuanian Lithuania, 28 Finnish Finland, 29 German (SW) Switzerland, 30 Estonian Estonia, 31 Latvian Latvia, 32 French (BE) Belgium, 33 French (SW) Switzerland, 34 Italian (SW) Switzerland, 36 French (Int) International French, 40 Bulgarian Bulgaria, 41 Belarusian Belarus, 43 Ukrainian Ukraine, 44 Serbian Serbia, 45 Romanian (RO) Romania, 46 German (Int) International German, 48 Croatian Croatia, 49 Macedonian Macedonia, 50 Slovenian Slovenia, 51 Hebrew Israel, 71 Catalan Catalonia (Spain), 80 Chinese China, 99 English (Int) International English

3. Scope of the approval does not indicate the operation of the network functionality



E Mattie-Suleiman, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 14 March 2023

Issue number: 03

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.