



# INCERT CERTIFICATE C-001-1548



Issued 04-12-2020 Replaces C-001-0650/a  
Expiry date 03-12-2026 Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: DGP (Data Gathering Panel)  
Trademark: Interlogix  
Type designation: ATS1238  
Hardware / Software: 55-950 rev B / V2.3

Placed on the market under the name or trademark of:

Name of the manufacturer: UTC Fire & Security B.V.  
Address: Kelvinstraat 7  
City: 6003DH Weert  
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: UTC Fire & Security EMEA bvba  
Address: De Kleetlaan 3  
City: 1831 Diegem  
Country: Belgium

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

Telefication B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



# CERTIFICATE

**Remarks and observations**

The following conditions are applicable:

Category: Wireless interface

Security grade: 2

Environmental class: II

Equipment class: Fixed

The ATS1238 is meant to be installed in a UTC Fire and Security alarm control panel enclosure ATS1000A-IP-LP and ATS1000A-LP.

The ATS1238 can also be placed outside a UTC Fire and Security alarm control panel enclosure using the ATS7072 kit. The ATS7072 kit consists of the ATS7070 (master) and ATS7071 (slave) and the housing TX-9000-03-1. The ATS1238 will be placed inside the TX-9000-03-1.

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Factory location:

UTC Fire & Security México corporation, S. de R.L. de C.V.

Boulevard 1 Eje C Parque Industrial

Navojoa

Mexico

**Documentation lodged for this INCERT certificate**

Test Reports:

- Telefication B.V.: 20103407800 - Rev. 4.0, 25 June 2014
- Telefication B.V.: 20124226200rev1.0, 10 July 2013
- Telefication B.V.: 20124226800rev1.0, 10 July 2013
- Telefication B.V.: 20124226801rev1.0, 10 July 2013
- Telefication: 160100453-004-Ver 2.00, 22 December 2017
- Telefication B.V.: 191100963-006-Ver 1.00, 25 March 2020
- Telefication B.V.: 200501100-001-Ver 1.00, 25 November 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1 February, 2018

**Applied Standards**

EN 50130-5	June, 2011
EN 50131-5-3	March, 2017
EN 50131-3	March, 2009
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017

**The product as described in this certificate includes the following type designations**

- Product description: DGP (Data Gathering Panel)
- Trademark: Interlogix
- Type designation: ATS1238
- Hardware version: 55-950 rev B
- Software version: V2.3