

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1281

In compliance with the Construction Product Regulations 2019, UK Statutory Instruments 2019 No.465 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

DM2010E Analogue Addressable Surface Mounting Type A Glass Outdoor Manual Call Point for use in fire detection and alarm systems

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Carrier Fire & Security B.V.
Kelvinstraat 7
NL-6003 DH
Weert
The Netherlands

Honeywell Life Safety Romania S.R.L
Strade Salcânilor 2 bis
Lugoj
Timis
305500
Romania

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-11:2001 + A1:2005 Manual Call Points

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 05 October 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 05 October 2022

Issue Date: 05 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1281

DM2010E Analogue Addressable Surface Mounting Type A Glass Outdoor Manual Call Point for use in fire detection and alarm systems

**** LEFT BLANK INTENTIONALLY ****



P Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 05 October 2022

Issue Date: 05 October 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com