





Date : 19 December 2022

CERTIFICATE OF COMPLIANCE

This certificate of compliance validates the following			
TEST REPORT NUMBER 'Assessment Reports' are not acceptable	TE223666	CERTIFICATE NUMBER	1062e
DATE OF ISSUE	5 April 2006	DATE OF ISSUE	21 March 2022
DATE OF EXPIRY	N/A	DATE OF EXPIRY	N/A
Manufacturer details			
NAME OF FACTORY/ MANUFACTURER	Honeywell Life Safety Romania S.R.L	NAME OF THE BRAND	Ziton
FACTORY ADDRESS / REGION (STREET / TOWN / CITY / COUNTRY)	Strade Salcânilor 2 bis Lugoj Timis 305500 Romania	MODEL / NO	ZP785-3 (172101)
WEBSITE	http://www.hls-romania.com/	LOGO ON THE PRODUCT	
TEL	+40 256 350 000	EMAIL	hls-romania@honeywell.com



TEL
BRE GLOBAL LTD
DOORNALLS LANE
WATFORD
WD25 9XX, UK



Product Details From Test Report		Reference Test Report page NO															
DESCRIPTION OF THE PRODUCT (TECHNICAL DETAILS FROM TEST REPORT, SUCH AS ACTUAL FIRE RATINGS/DIMENSIONS/THICKNESS/ SENSITIVITY ETC)	ZP785-3 Analogue Addressable Type A Indoor Manual Call Point Accessories: DMN787 Surface mounting box with earth terminal, red DMN790 Flush mount cradle with connectors DMN795 Flush mount cradle with connectors and forkgrrips DMN782 Hinged transparent MCP protection cover DMN715 EN 54 universal MCP glass DMN784 Call point test key DMN800 Resettable element																
TEST STANDARD (SUCH AS ASTM/BS EN/ DN ETC)	EN 54-11:2001 + A1:2005																
TEST DESCRIPTION	The object of this evaluation was to examine the construction and assess the performance of the G.E Security (Africa) trading as Ziton (Pty) Ltd Model ZP785-3 analogue addressable manual call point for compliance with the requirements of EN 54: Part 11: 2001 ¹ .																
SPECIFICATION OF TEST SPECIMEN	First Submission <table border="1"> <thead> <tr> <th colspan="3">Equipment</th> </tr> <tr> <th>No.</th> <th>Description</th> <th>Receipt date</th> </tr> </thead> <tbody> <tr> <td>29</td> <td>ZP785-3 Addressable Manual Call point with glass elements</td> <td>02.02.05</td> </tr> <tr> <td>10</td> <td>Re-settable (plastic) elements</td> <td>18.11.05</td> </tr> <tr> <td>1</td> <td>Ziton ZP3 Control Panel serial number 104030015</td> <td>Already at BRE</td> </tr> </tbody> </table>	Equipment			No.	Description	Receipt date	29	ZP785-3 Addressable Manual Call point with glass elements	02.02.05	10	Re-settable (plastic) elements	18.11.05	1	Ziton ZP3 Control Panel serial number 104030015	Already at BRE	
Equipment																	
No.	Description	Receipt date															
29	ZP785-3 Addressable Manual Call point with glass elements	02.02.05															
10	Re-settable (plastic) elements	18.11.05															
1	Ziton ZP3 Control Panel serial number 104030015	Already at BRE															
TEST RESULT (SUCH AS PASSED CRITERIA ___/ COMPLIED TO ___/ DURATION ___/ OBSERVATION ___/ ETC)	<p>The G.E Security (Africa) trading as Ziton (Pty) Ltd Model ZP785-3 analogue addressable manual call point met the requirements of Clauses 4.2.2 Data, 4.3 Normal condition, 4.4 Indicators for alarm condition, 4.5 Resel facility, 4.7 Construction and design, 5.2 Operational performance test, 5.3 Function test, 5.4 Test facility test, 5.5 Reliability test, 5.6 Variation of supply parameters, 5.7 Dry heat, 5.9 Cold, 5.10 Damp heat, cyclic, 5.12 Damp heat, steady state, 5.13 SO₂ corrosion endurance, 5.14 Shock (operational), 5.15 Impact (operational), 5.16 Vibration, sinusoidal (operational), 5.17 Vibration sinusoidal (endurance), 5.18.2.1(a) Electrostatic discharge, 5.18.2.1(b) Radiated electromagnetic fields, 5.18.2.1(c) Conducted disturbances induced by electromagnetic fields, 5.18.2.1(d) Fast transient bursts and 5.18.2.1(e) Slow high energy voltage surges of EN 54-11: 2001¹ on the first submission.</p> <p>The requirements of Clause 4.2.1 Marking, were met on the second submission when the label was modified to incorporate additional information.</p> <p>The requirements of Clause 4.8 - Additional requirements for software controlled manual call points was evaluated in Software report TE223666SW²</p>																
PRODUCT APPLICATION GUIDELINE (END USE) (CLEARLY STATE THE END USE WITH SPECIFIC APPLICATION, SUCH AS EXACT FIRE RATING/TO BE INSTALLED IN ___/TO BE INSTALLED AT ___/TO BE CONNECTED WITH ___/TO BE INSTALLED WITH ___ ETC ALONG WITH ANY WARNINGS SUCH AS NOT TO BE USED IN ___/NOT TO BE INSTALLED AT ___/ NOT TO BE INSTALLED WITH ___ ETC.	Installation Sheet 20-8030-501-2003 (D1065-11) 10 June 2022  BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK																



Laboratory and Certification body details

NAME OF CERTIFICATION BODY	BRE Global Ltd.	NAME OF TEST FACILITY	BRE Global Ltd.
CERTIFICATION BODY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Bucknalls Lane Garston Watford WD25 9XX United Kingdom	TEST FACILITY ADDRESS / REGION <small>(STREET / TOWN / CITY / COUNTRY)</small>	Bucknalls Lane Garston Watford WD25 9XX United Kingdom
WEBSITE	https://www.bregroup.com/about-us/bre-global/	WEBSITE	https://www.bregroup.com/about-us/bre-global/
TEL	+44 (0)333 321 88 11	TEL	+44 (0)333 321 88 11
EMAIL	BREGlobalEnquiries@bregroup.com	EMAIL	BREGlobalEnquiries@bregroup.com
ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE CERTIFICATION BODY, ALONG WITH WEBSITE)</small>	UKAS www.ukas.com	ACCREDITED BY <small>(NAME OF ACCREDITATION BODY WHICH ISSUED ACCREDITATION TO THE LABORATORY, ALONG WITH WEBSITE)</small>	UKAS www.ukas.com
AS PER <small>(STANDARD TO WHICH THE CERTIFICATION BODY IS ACCREDITED TO)</small>	EN45011: 1998 / ISO 17065: 2012	AS PER <small>(STANDARD TO WHICH YOUR ORGANIZATION IS ACCREDITED TO)</small>	ISO 17025: 2017
VALIDITY <small>(EXPIRY DATE OF CERTIFICATION BODY ACCREDITATION)</small>	N/A	VALIDITY <small>(EXPIRY DATE OF LABORATORY ACCREDITATION)</small>	N/A
REFERENCE NUMBER: <small>(CERTIFICATION BODY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	0007	REFERENCE NUMBER: <small>(THE LABORATORY ACCREDITATION REFERENCE NUMBER TO VERIFY ON THE ACCREDITOR'S WEBSITE)</small>	0578
CERTIFICATION MARK	  BRE GLOBAL LTD. BUCKNALLS LANE WATFORD WD25 9XX, UK		



(ENDORSEMENT) TO BE SIGNED BY MANUFACTURER			
NAME OF MANUFACTURER'S SIGNATORY	Jim Clarke	SIGNATURE	
EMAIL / TEL	Jim.clarke@honeywell.com +44 (0)1403 226235	FACTORY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

(ENDORSEMENT) TO BE SIGNED BY CERTIFICATION BODY			
NAME OF CERTIFICATION BODY SIGNATORY	BRE Global Ltd.	SIGNATURE	
EMAIL / TEL	BRGlobalEnquiries@bregroup.com +44 (0)333 321 88 11	CERTIFICATION BODY OFFICIAL SEAL	
NOTES: I Undertake that all data and information provided are genuine and accurate			

ATTACHMENTS:

- COPY OF 'CERTIFICATE OF COMPLIANCE' ISSUED BY CERTIFICATION BODY (OLD OR NEW)