

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F1706

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

58000-400 Discovery Analogue Addressable Class P Heat Detector

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

and produced in the manufacturing plant(s):

Apollo Fire Detectors Limited
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 12 June 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 12 June 2018

Date of Issue: 12 June 2018

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F1706**58000-400 Discovery Analogue Addressable Class P Heat Detector****Notes:**

1. Meets the requirements of EN54: Part 5 at the following modes:

- Class A1R in Mode 1 and in Conventional Alarm Mode
- Class A2 in Mode 2 and in Conventional Alarm Mode
- Class A2S in Mode 3 and in Conventional Alarm Mode
- Class CR in Mode 4 and in Conventional Alarm Mode
- Class CS in Mode 5 and in Conventional Alarm Mode

Bases:

45681-210 XP95 Mounting Base

45681-209 XP95/Discovery Standard Deep Mounting Base

Variant:

58000-400SIL Discovery Analogue Addressable Class P Heat Detector



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 12 June 2018

Date of Issue: 12 June 2018

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.