

**DECLARATION OF PERFORMANCE**

305/2011/EU szerint

1. Unique identification code of the product type:

**ENICOM Security and Fire Communicator**

2. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer

**Alarm and trouble signal transmission equipment for use in detection and alarm systems**

3. Name, registered trade name or trade mark and contact address of the manufacturer (art.11(5))

**VILLBAU Biztonságtechnika Kft.**  
1182 Budapest, Üllői út 611.  
Tel: +36 1 2975125, Fax: +36 1 2942928  
web: [www.villbau.com](http://www.villbau.com), e-mail: [mail@villbau.com](mailto:mail@villbau.com)

4. Where applicable, name and contact address of the authorised representative (art. 12(2))

**Not relevant**

5. Assessment and verification system of constancy of building product properties

**System 1, (Annex V, point 1.2 of EU Directive No. 305/2011/EU issued on 9.3.2011)**

6. In case of the Declaration of Performance covered by harmonised standard:

**ÉMI Építésügyi Minőségellenőrző Innovációs Nonprofit Kft., Notified Body Number: 1415, Fire Protection Department Laboratory, 2000 Szentendre, Dózsa György út 26., accredited laboratory under NAT-1-1110/2018/K issued Certification of Conformity according to EN54-21:2006 under**

**1415-CPR-110-(C-3/2022)****as the base of this declaration.**

7. Declared performance

Essential characteristic	Performance	Harmonized technical specification
Transmission time	DP4, SP5 < 10 s	<b>EN 54-21:2006</b>
Maximal transmission time	M4 < 30 s	
Reporting time	T5 < 90 s	
Reliability of operation	A4 > 99.8%	
Information security	NPD / I0	
Resistance to heat	Environmental Class II	
Resistance to vibration	Environmental Class II	
Resistance to humidity	Environmental Class II	

8. Number of the technical measurement and test specifications: CT-M449K-23946-2021 (C-3/2022)

The performance of the product identified above is in full conformity with the properties in point 7. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Budapest, 16-09-2022

**VILLBAU Kft. 5.**  
**BIZTONSÁGTECHNIKA**  
1182. Bp., Üllői út 611.  
Adósz.: 13194693-2-43

VASS DÁNIEL  
general manager