



## DECLARATION OF CONFORMITY

**We,** Teletek Electronics JSC  
**Address:** 2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria

**Declares that the**

**Product:** SensoIRIS S130 IS  
**Description:** Analogue addressable fire alarm optical- smoke detector with built-in isolator module

**Complies to the following standards:**

EN 54-7:2018  
EN 54-17:2005; EN 54-17:2005/AC:2007  
EN 55032:2015  
EN 50130-4:2011/A1:2014

**The following Regulation:**

CPR № 305/2011  
REACH No 1907/2006

**And the following Directives:**

2014/30/EU- EMC  
2011/65/EU- RoHS II

**Additional information:**

**First date of production:** 09.2011

**Certificate:**

№ 1293–CPR-0451-Rev.2 of November 6<sup>th</sup>, 2023 from Notified body № 1293 EVPU

**Test Report:**

№ C08/21/0026/4204, 4206/SL-5 of May 20, 2022 from Notified body № 1293 EVPU

**Note:** To be used in conjunction with base B124.

2, Iliyansko shose Str.  
NPZ Voenna Rampa  
1220 Sofia, Bulgaria  
08.12.2023

Yuliy Iliev  
Quality Manager



1293