

# CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)  
Notified Body Nr. 0370

No. **0370-CPR-6988**

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

## **FIRE DETECTION AND FIRE ALARM SYSTEMS:**

- **INPUT/OUTPUT DEVICES.**
- **SHORT-CIRCUIT ISOLATORS.**

MODEL: **KE-IO3101** INTELLIGENT ADDRESSABLE OUTPUT UNIT WITH ISOLATOR - 1 OUTPUT (WHITE)

TRADEMARK: **KIDDE COMMERCIAL**

Placed on the market under the name of:

## **CARRIER FIRE & SECURITY B.V.**

KELVINSTRAAT, 7  
6003 DH WEERT (THE NETHERLANDS)

And produced in the manufacturing plant:

## **CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.**

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-17:2005, EN 54-17:2005/AC:2007; EN 54-18:2005, EN 54-18:2005/AC:2007**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 7<sup>th</sup> December 2023 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 22<sup>nd</sup> November 2024.

## **The monitoring assessment will be done before 31<sup>st</sup> July 2025**

Bellaterra, 22<sup>nd</sup> November 2024

  
LGAI Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*This document is not valid without its technical annex; whose number coincides with that of the certificate.*

*You can check the validity of this certificate on our website: [www.appluslaboratories.com/certified\\_products](http://www.appluslaboratories.com/certified_products)*

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

## 0370-CPR-6988

Annex according to **EN 54-17:2005, EN 54-17:2005/AC:2007**

### FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 17. SHORT-CIRCUIT ISOLATORS

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Compliance	4.1	PASS
Integral status indication	4.2	PASS
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	PASS
On-site adjustments	4.6	NA
Marking	4.7	PASS
Data	4.8	PASS
Additional requirements for software controlled short-circuit isolators	4.9	PASS
Reproducibility	5.2	PASS
Variation in supply voltage	5.3	PASS
Dry heat (operational)	5.4	PASS
Cold (operational)	5.5	PASS
Damp heat, cyclic (operational)	5.6	PASS
Damp heat, steady state (endurance)	5.7	PASS
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	5.8	PASS
Shock (operational)	5.9	PASS
Impact (operational)	5.10	PASS
Vibration, sinusoidal (operational)	5.11	PASS
Vibration, sinusoidal (endurance)	5.12	PASS
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

## 0370-CPR-6988

Annex according to **EN 54-18:2005, EN 54-18:2005/AC:2007**

### FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 18: INPUT/OUTPUT DEVICES

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Functional test	5.1.4.	PASS
Performance and variation in supply parameters	5.2	PASS
Dry heat (operational)	5.3	PASS
Cold (operational)	5.4	PASS
Damp heat, cyclic (operational)	5.5	PASS
Damp heat, steady state (endurance)	5.6	PASS
Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	5.7	PASS
Shock (operational)	5.8	PASS
Impact (operational)	5.9	PASS
Vibration, sinusoidal (operational)	5.10	PASS
Vibration, sinusoidal (endurance)	5.11	PASS
Electromagnetic Compatibility (EMC) Immunity tests	5.12	PASS

PASS; NPD = No Performance Determined; NA = Not Applicable

# CERTIFICADO DE CONSTANCIA DE LAS PRESTACIONES

LGAI Technological Center, S.A. (APPLUS)  
Organismo Notificado Nr. 0370

No.

0370-CPR-6988

En cumplimiento con el Reglamento (UE) No.305/2011 del Parlamento Europeo y del Consejo de 9 de marzo de 2011 (Reglamento de Productos de Construcción o CPR), este certificado aplica al producto de construcción:

## SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS:

- **DISPOSITIVOS DE ENTRADA/SALIDA.**
- **AISLADORES DE CORTOCIRCUITO.**

MODELO: **KE-IO3101** UNIDAD DE SALIDA DIRECCIONABLE INTELIGENTE CON AISLADOR – 1 SALIDA (BLANCO)  
MARCA: **KIDDE COMMERCIAL**

Puesto en el mercado por:

## CARRIER FIRE & SECURITY B.V.

KELVINSTRAAT, 7  
6003 DH WEERT (THE NETHERLANDS)

Y fabricado en la planta de producción:

## CARRIER SAFETY SYSTEM (HEBEI) CO., LTD.

No. 80 CHANGJIANG EAST ROAD, QETDZ, QINHUANGDAO, HEBEI, CHINA 066004

Este certificado acredita que se han aplicado todas las disposiciones relativas a la evaluación y verificación de la constancia de las prestaciones descritas en el Anexo ZA de las normas:

**EN 54-17:2005, EN 54-17:2005/AC:2007; EN 54-18:2005, EN 54-18:2005/AC:2007**

bajo el sistema 1, y que el control de producción en fábrica realizado por el fabricante se evalúa para garantizar la constancia de las prestaciones del producto de construcción.

Este certificado fue emitido por primera vez el 7 de diciembre de 2023 y su validez permanece mientras no se modifique significativamente la norma armonizada, el producto de construcción, los métodos de EVCP ni las condiciones de fabricación en la planta, a menos que sean suspendidos o retirados por el organismo de certificación de productos notificado. A fecha 22 de noviembre de 2024 se confirma éste y todas sus modificaciones anteriores.

## El seguimiento se realizará antes de 31 de julio de 2025

Bellaterra, 22 de noviembre de 2024

  
LGAI Technological Center, S.A.

Xavier Ruiz Peña  
Managing Director, Product Conformity B.U.



*Este documento carece de validez sin su anexo técnico, cuyo número coincide con el del certificado.*

*Puede comprobarse la validez de este certificado en nuestra página web: [www.appluslaboratories.com/certified\\_products](http://www.appluslaboratories.com/certified_products)*

El fabricante, después de completar el procedimiento de evaluación de la conformidad y la declaración de prestaciones, puede colocar el marcado CE bajo su responsabilidad

## 0370-CPR-6988

Anexo según **EN 54-17:2005, EN 54-17:2005/AC:2007**

### SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. PARTE 17: AISLADORES DE CORTOCIRCUITO

CARACTERÍSTICAS ESENCIALES	CAPÍTULO Y APARTADOS EN ESTA NORMA EUROPEA	NIVELES Y/O CLASES MANDATADAS
Cumplimiento	4.1	PASA
Indicación integral del estado	4.2	PASA
Conexión de los dispositivos auxiliares	4.3	NA
Monitorización de los aisladores de cortocircuito desmontables	4.4	NA
Ajustes del fabricante	4.5	PASA
Ajustes en el sitio	4.6	NA
Marcado	4.7	PASA
Datos	4.8	PASA
Requisitos adicionales para los aisladores de cortocircuito controlados por software	4.9	PASA
Reproducibilidad	5.2	PASA
Variación en la tensión de suministro	5.3	PASA
Calor seco (operacional)	5.4	PASA
Frio (operacional)	5.5	PASA
Calor húmedo cíclico (operacional)	5.6	PASA
Calor húmedo, estado estacionario (resistencia)	5.7	PASA
Corrosión por Dióxido de Azufre	5.8	PASA
Choque(operacional)	5.9	PASA
Impacto	5.10	PASA
Vibración, Sinusoidal (operacional)	5.11	PASA
Vibración, Sinusoidal (resistencia)	5.12	PASA
EMC (inmunidad)	5.13	PASA

PASA; PND = Prestación No Determinada, NA = No Aplica

## 0370-CPR-6988

Anexo según **EN 54-18:2005, EN 54-18:2005/AC:2007**

### **SISTEMAS DE DETECCIÓN Y ALARMA DE INCENDIOS. PARTE 18: DISPOSITIVOS DE ENTRADA/SALIDA**

CARACTERÍSTICAS ESENCIALES	CAPÍTULO Y APARTADOS EN ESTA NORMA EUROPEA	NIVELES Y/O CLASES MANDATADAS
Ensayo funcional	5.1.4.	PASA
Comportamiento y variación en los parámetros de funcionamiento	5.2	PASA
Calor seco (funcional)	5.3	PASA
Frío (operacional)	5.4	PASA
Calor húmedo cíclico (funcional)	5.5	PASA
Calor húmedo estado estacionario (resistencia)	5.6	PASA
Corrosión por dióxido de azufre	5.7	PASA
Choque (operacional)	5.8	PASA
Impacto (operacional)	5.9	PASA
Vibración sinusoidal (operacional)	5.10	PASA
Vibración sinusoidal (resistencia)	5.11	PASA
EMC	5.12	PASA

PASA; PND = Prestación No Determinada; NA = No Aplica