



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: SensoIRIS MCP150 IP67

Description: Intelligent analogue addressable fire alarm manual call point with built-in isolator module

Complies with the following standard:

EN 54-11:2001, EN 54-11:2001/A1:2005
EN 54-17:2005, EN 54-17:2005/AC:2007
IEC 60529:1989 + A1:1999 + A2: 2013
EN 55032:2015
EN 50130-4:2011+A1:2014

The following Regulation:

CPR № 305/2011
REACH No 1907/2006

And the following Directives:

2014/30/EC- EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 11.2016

Certificate:

№1293–CPR-0538 Rev.2
№ 00005/101/1/2017

of September 29th, 2023 from Notified body № 1293 EVPU
of February 08, 2017 from Notified body № 1293 EVPU

Test report:

№ C08/16/0026/4206/CA Rev.1 of August 07, 2017 from Notified body № 1293 EVPU

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
11.12.2023

Yuliy Iliyev
Quality Manager



1293