



003-PROD
ISO/IEC 17065

BOSEC

CERTIFICATE

N° B - 9077 - FD - K 618-d

We certify that the fire detection component:

HEAT DETECTOR APOLLO
Orbis IS ORB-HT-51145 with SensAlert/FasTest (A1R)
Variant : Orbis IS ORB-HT-51146-APO with Flashing LED/SensAlert/FasTest (A1R)
Orbis IS ORB-HT-51147-APO with SensAlert/FasTest (A2S)
Variant: ORB-HT-51148-APO with Flashing LED/SensAlert/FasTest (A2S)
Orbis IS ORB-HT-51149-APO with SensAlert/FasTest (BR)
Variant: ORB-HT-51150-APO with Flashing LED/SensAlert/FasTest (BR)
Orbis IS ORB-HT-51151-APO with SensAlert/FasTest (BS)
Variant: ORB-HT-51152-APO with Flashing LED/SensAlert/FasTest (BS)
Orbis IS ORB-HT-51153-APO with SensAlert/FasTest (CR)
Variant: ORB-HT-51154-APO with Flashing LED/SensAlert/FasTest (CR)
Orbis IS ORB-HT-51155-APO with SensAlert/FasTest (CS)
Variant: ORB-HT-51156-APO with Flashing LED/SensAlert/FasTest (CS)
Orbis IS ORB-HT-51157-APO with SensAlert/FasTest (A1S)
Variant: ORB-HT-51158-APO with Flashing LED/SensAlert/FasTest (A1S)
BASE ADAPTER: ORBIS IS ORB-BA-50008-APO (only in conjunction with base 45681-207)
BASE : ORBIS IS ORB-MB-50018-APO

Manufactured at Havant (U.K.)

comply with the following specifications :

BOSEC Mark Rules : Products Certification (BOSEC - Products rules E dd 20131003) and Administrative and Legal Clauses (BOSEC - Admin Legal Rules E dd 20131003)
EN 54-5:2000/A1:2002

on the base of the report of the laboratories ANPI & EC(CPD) Certificates of conformity:

BFS/REDI/421-2013.02.13 & 0832-CPD-0469-05/09/2006-Iss 2, 0832-CPD-0470-05/09/2006-Iss 2, 0832-CPD-0471-05/09/2006-Iss 2, 0832-CPD-0472-05/09/2006-Iss 2, 0832-CPD-0473-05/09/2006-Iss 2, 0832-CPD-0474-05/09/2006-Iss 2, 0832-CPD-0475-05/09/2006-Iss 2

*This certificate is only valid if the **detectors** are provided with the mark **BOSEC**.*

The company

**APOLLO FIRE DETECTORS LTD.,
36 Brookside Road
HAVANT, HAMPSHIRE, PO9 1JR
UNITED KINGDOM**

*is authorised to use the mark **BOSEC** on the above mentioned **detectors**.*

*This certificate is granted subject to the **ANPI**
terms and conditions and is valid until*

the 23rd of April 2028

*signed on behalf of **ANPI**
Brussels, the 21st of March 2016*

*The General Secretary
M. Vandendoren*

asbl **ANPI** vzw - Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve
Tel: +32.10.47.52.11 Fax: +32.10.47.52.70 Email: info@anpi.be Internet: www.anpi.be

This certificate may only be copied completely and without any adding.



003-PROD
ISO/IEC 17065

BOSEC

CERTIFICAT

N° B - 9077 - FD - K 618-d

Nous certifions que le composant de détection incendie:

DETECTEUR DE CHALEUR APOLLO
Orbis IS ORB-HT-51145 with SensAlert/FasTest (A1R)
Variante : Orbis IS ORB-HT-51146-APO with Flashing LED/SensAlert/FasTest (A1R)
Orbis IS ORB-HT-51147-APO with SensAlert/FasTest (A2S)
Variante: ORB-HT-51148-APO with Flashing LED/SensAlert/FasTest (A2S)
Orbis IS ORB-HT-51149-APO with SensAlert/FasTest (BR)
Variante: ORB-HT-51150-APO with Flashing LED/SensAlert/FasTest (BR)
Orbis IS ORB-HT-51151-APO with SensAlert/FasTest (BS)
Variante: ORB-HT-51152-APO with Flashing LED/SensAlert/FasTest (BS)
Orbis IS ORB-HT-51153-APO with SensAlert/FasTest (CR)
Variante: ORB-HT-51154-APO with Flashing LED/SensAlert/FasTest (CR)
Orbis IS ORB-HT-51155-APO with SensAlert/FasTest (CS)
Variante: ORB-HT-51156-APO with Flashing LED/SensAlert/FasTest (CS)
Orbis IS ORB-HT-51157-APO with SensAlert/FasTest (A1S)
Variante: ORB-HT-51158-APO with Flashing LED/SensAlert/FasTest (A1S)
ADAPTATEUR DE SOCLE : ORBIS IS ORB-BA-50008-APO (only in conjunction with base 45681-207)
SOCLE : ORBIS IS ORB-MB-50018-APO

Fabriqu      Havant (U.K.)

r  pond aux prescriptions suivantes :

R  glement de la marque BOSEC : R  gles de certification Produits (BOSEC - Products rules F dd 20131003) et
Clauses administratives et juridiques (BOSEC - Admin Legal Rules F dd 20131003.doc)
EN 54-5:2000/A1:2002

sur base du rapport d'essais des laboratoires ANPI & Certificats de Conformit   CE (CPD):

BFS/REDI/421-2013.02.13 & 0832-CPD-0469-05/09/2006-Iss 2, 0832-CPD-0470-05/09/2006-Iss 2, 0832-CPD-0471-05/09/2006-Iss 2,
0832-CPD-0472-05/09/2006-Iss 2, 0832-CPD-0473-05/09/2006-Iss 2, 0832-CPD-0474-05/09/2006-Iss 2, 0832-CPD-0475-05/09/2006-Iss 2

*Le certificat n'est valable que si les d  tecteurs sont pourvus du label **BOSEC**.*

La firme

**APOLLO FIRE DETECTORS LTD.,
36 Brookside Road
HAVANT, HAMPSHIRE, PO9 1JR
UNITED KINGDOM**

*est habilit  e    apposer la marque **BOSEC** sur les d  tecteurs ci-dessus.*

*Ce certificat est d  livr   aux conditions d  finies par
ANPI et est valable jusqu'au*

23 avril 2028

*sign   au nom de **ANPI**
Bruxelles, le 21 mars 2016*

*Le Secr  taire G  n  ral
M. Vandendoren*

asbl **ANPI** vzw - Parc scientifique Fleming - Granbonpr   1 B-1348 Louvain-La-Neuve

T  l: +32.10.47.52.11 Fax: +32.10.47.52.70 Email: info@anpi.be Internet: www.anpi.be

Ce certificat ne peut   tre reproduit que dans son enti  ret   et sans aucune surcharge.



003-PROD
ISO/IEC 17065

BOSEC

CERTIFICAAT

N^r B - 9077 - FD - K 618-d

Wij certificeren dat het branddetectiecomponent:

Gefabriceerd te Havant (U.K.)

WARMTEMLDER APOLLO

Orbis IS ORB-HT-51145 with SensAlert/FasTest (A1R)

Variant : Orbis IS ORB-HT-51146-APO with Flashing LED/SensAlert/FasTest (A1R)

Orbis IS ORB-HT-51147-APO with SensAlert/FasTest (A2S)

Variant: ORB-HT-51148-APO with Flashing LED/SensAlert/FasTest (A2S)

Orbis IS ORB-HT-51149-APO with SensAlert/FasTest (BR)

Variant: ORB-HT-51150-APO with Flashing LED/SensAlert/FasTest (BR)

Orbis IS ORB-HT-51151-APO with SensAlert/FasTest (BS)

Variant: ORB-HT-51152-APO with Flashing LED/SensAlert/FasTest (BS)

Orbis IS ORB-HT-51153-APO with SensAlert/FasTest (CR)

Variant: ORB-HT-51154-APO with Flashing LED/SensAlert/FasTest (CR)

Orbis IS ORB-HT-51155-APO with SensAlert/FasTest (CS)

Variant: ORB-HT-51156-APO with Flashing LED/SensAlert/FasTest (CS)

Orbis IS ORB-HT-51157-APO with SensAlert/FasTest (A1S)

Variant: ORB-HT-51158-APO with Flashing LED/SensAlert/FasTest (A1S)

VOETSTUK ADAPTER: ORBIS IS ORB-BA-50008-APO (only in conjunction with base 45681-207)

VOETSTUK : ORBIS IS ORB-MB-50018-APO

beantwoordt aan de volgende voorschriften :

Reglement van het BOSEC-merk : certificatieregels Producten (BOSEC - Products rules N dd 20131003) en de Administratieve en juridische clausules (BOSEC - Admin Legal Rules N dd 20131003)
EN 54-5:2000/A1:2002

op basis van de laboratoria ANPI beproevingsverslag & EG - CPD Conformiteitscertificaten:

BFS/REDI/421-2013.02.13 & 0832-CPD-0469-05/09/2006-Iss 2, 0832-CPD-0470-05/09/2006-Iss 2, 0832-CPD-0471-05/09/2006-Iss 2, 0832-CPD-0472-05/09/2006-Iss 2, 0832-CPD-0473-05/09/2006-Iss 2, 0832-CPD-0474-05/09/2006-Iss 2, 0832-CPD-0475-05/09/2006-Iss 2

*Het certificaat is alleen geldig indien de **detectoren** van het merk **BOSEC** voorzien zijn.*

De firma

**APOLLO FIRE DETECTORS LTD.,
36 Brookside Road
HAVANT, HAMPSHIRE, PO9 1JR
UNITED KINGDOM**

*heeft toestemming om het merk **BOSEC** op de bovenvermelde **detectoren** te gebruiken.*

*Dit certificaat werd afgeleverd onder de door
ANPI bepaalde voorwaarden en is geldig tot*

23 april 2028

*ondertekend namens **ANPI***

Brussel, 21 maart 2016

*De Secretaris-Generaal
M. Vandendoren*

asbl **ANPI** vzw - Parc scientifique Fleming - Granbonpré 1 B-1348 Louvain-La-Neuve

Tel: +32.10.47.52.11 Fax: +32.10.47.52.70 Email: info@anpi.be Internet: www.anpi.be

Dit certificaat mag alleen in zijn geheel en zonder enige toevoeging gereproduceerd worden.