

# CERTIFICATE

### of constancy of performance

1922 - CPR - 1230

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Fire detection and fire alarm systems. Fire alarm devices. Sounders. Conventional indoor fire alarm sounder - SV2002F and SF105

(For list of controlled characteristics and models, see Annexes I and II to 1922-CPR-1230 that are an inseparable part of this certificate)

placed on the market under the name or trade mark of

Safety Technics and Systems No.31 "3020" Str., 1360 Sofia, Bulgaria

and produced in the manufacturing plant of

Safety Technics and Systems No.31 "3020" Str., 1360 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

#### EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 19.07.2019 and will remain valid until 19.07.2024 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.









Manager:

dipl. eng. Anna Vasileva



## ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 1230/19.07.2021

#### Model SF105 - Conventional indoor fire alarm sounder

Performance list, acc. to EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Essential Characteris	tics Performa	ince Clause
Performance parameters under fire conditions		
- Sound level	Pass	4.2
<ul> <li>Frequencies and sound pattern</li> </ul>	Pass	4.3
- Reproducibility	Pass	5.2
- Operational performance	Pass	5.3
<ul> <li>Attention drawing signal and message broad</li> </ul>	cast sequences N/A	C.3.1
- Synchronisation	N/A	C.3.2
- Broadcast message performance	N/A	C.5.1
- Attention drawing signal/silence/message se	quence timing N/A	C.5.2
- Message synchronization testing	N/A	C.5.3
Operational reliability		
- Durability	Pass	4.4
- Construction	Pass	4.5
- Marking and data	Pass	4.6
- Durability	Pass	5.4
- General testing	N/A	C.4
Durability of operational reliability, temperature	resistance	
- Dry heat (operational)	Pass	5.5
- Dry heat (endurance)	N/A	5.6
- Cold (operational)	Pass	5.7
- Damp heat, cyclic (operational)	Pass	5.8
<ul> <li>Damp heat, steady state (endurance)</li> </ul>	Pass	5.9
Durability of operational reliability, humidity resis	tance	
- Damp heat, cyclic (operational)	Pass	5.8
- Damp heat, steady state (endurance)	Pass	5.9
- Damp heat, cyclic (endurance)	N/A	5.10
Durability of operational reliability, corrosion res	stance	
- Sulphur dioxide (SO2) corrosion (endurance)	Pass	5.11
Durability of operational reliability, shock and vib	ration resistance	
- Shock (operational)	Pass	5.12
- Impact (operational)	Pass	5.13
- Vibration, sinusoidal (operational)	Pass	5.14
- Vibration, sinusoidal (endurance)	Pass	5.15
Durability, electrical stability		
- Electromagnetic compatibility (EMC), immun	ity (operational) Pass	5.16
Durability of operational reliability, resistance to i		
- Enclosure protection	Pass	5.17





sad stamp of "Dedal Acc.

Attestation & Certification

Manager:

Issued: Burgas, 19 July 2021 Ref. No. 01-00